



*12323 Windsor Road  
Chester, VA 23831  
O 804-930-1007  
F 804-930-1008*

May 13, 2018

Janice Bridgers  
12908 Cherrywood Lane  
Bowie, Maryland 20715

**Re: Lot 510, Caroline Pines  
TM #93A3-1-510  
Caroline County, Virginia**

Dear Ms. Bridgers:

Per your request we evaluated the soils on the referenced property for septic tank drainfield site suitability. Several soil borings were conducted. Due to shallow depth to the seasonal water table and insufficient area of suitable soils, a conventional drainfield site could not be found on the property.

An area was found for an alternative septic system with a shallow-placed pad with TL-3 treatment and UV disinfection. This area will accommodate a three-bedroom, 450 gallons per day system.

If you need any additional information, please let us know.

Sincerely,

*Larry W. Madison Jr*

Larry W. Madison, Jr.  
AOSE #1940 001076